

# ENERGY AUDIT OF INSTITUTION WITH LOAD 430kW

<sup>1</sup>AMARJEET S. PANDEY, <sup>2</sup>GAURI R. KADAM, <sup>3</sup>ADITYA A. RUGLE

*Department of Electrical Engg., Sanjivani College of Engg., Kopargaon<sup>1,2,3</sup>*  
*E-mail: <sup>1</sup>pandey.amarjeet73@gmail.com, <sup>2</sup>kadamgauri1998@gmail.com, <sup>3</sup>a2rugle789@gmail.com*

\*\*\*\*\*

**Abstract:** The objective of this paper is to demonstrate the findings of the Energy Audit done at the Campus of Sanjivani College of Engineering, Kopargaon. An energy audit is a study of plant or facility to determine how and where energy is used and to identify methods for energy savings. There is now a universal recognition of the fact that new technologies and much greater use of some that already exist provide the most hopeful prospects for the future. The opportunities lie in the use of existing renewable energy technologies, greater efforts at energy efficiency and the dissemination of these technologies and options. Our objective of doing energy audit at, Sanjivani College of Engineering Campus, Kopargaon is to identify and arrest the wastage of electricity and to make effective use of electricity in college campus and thus reducing electricity bill of college campuses. It is aimed at obtaining a detailed idea about various end use energy consumption activities at various departments in the campus and comparing it to the actual consumption of electricity.

\*\*\*\*\*

## I INTRODUCTION

The prime input of energy in Sanjivani College of Engineering Campus is electricity i.e. electrical energy. Our main focus is conservation and management of electricity. We will be mainly covering the electrical appliances for energy audit. These electrical appliances consume lot of electrical energy which gives us a chance to save and manage it up to certain extent. Electrical energy losses occur due to improper management, human errors etc. We have confined our project level for domestic appliances like tube lights, bulbs, fan, air conditioners, switches, computers, servers, etc. After going through detail observations and calculations, in this paper, we have put the findings of the loadings in various departments of Sanjivani College of Engineering Campus, Kopargaon.

## II. DATA COLLECTION-

In preliminary data collection phase, exhaustive data collection was made using different methods such as observations, interviewing key persons, and measurements. During we visited each department, center, laboratories, solar shed and other entities of the institution. Information about the general electrical appliances was collected by observation and interviewing. We also collected information of Electricity bill from the in-charge personnel. The power consumption of appliances was measured using power analyzer in some cases (such as fans) while in other cases, rated power was used (light for example). We also collected information on redundant / non-operational energy systems. The details of usage of the appliances were collected by interviewing key persons e.g. electrician, caretaker (in case of departments) etc. Approximations and generalizations were done at places with lack of information.

## III. ANALYSIS-

### A. Analysis of Area of Use -

Identifying where energy is used is useful because it identifies which areas the audit should be focused on and raises awareness of energy use and cost. We have found that the Electrical Energy used is primarily in departments on tube lights, bulbs, fan, air

conditioners, switches, computers, servers, swtichboards etc. After collecting data, we made calculations to find out the difference between our calculated total energy consumption and the energy consumption recorded in the Electricity bill of the college.

### B. Mathematical Formulae-

During the calculations in electrical audit of Sanjivani College of Engg. Campus, Kopargaon, we used the following formulas to obtain values of energy consumption.

i) Diversity Factor =

$$\frac{\text{Total Connected Load}}{\text{Maximum Load}}$$

ii) Demand Factor =

$$\frac{\text{Maximum Demand}}{\text{Connected Load}}$$

iii) Load Factor =

$$\frac{\text{Average Load}}{\text{Connected Load}}$$

iv) Maximum Demand =


$$\frac{\text{Connected Load}}{\text{Diversity Factor}}$$

### C. Calculations-

The calculation of various departments is made as follows-


*i. Electrical Department-*

| Equipment Name (Rating in Watts) | Qty. | Total Consumption                  |
|----------------------------------|------|------------------------------------|
| Fan(40)                          | 50   | 2000                               |
| Tubelight(LED)(18)               | 44   | 792                                |
| Tubelight(Fluorescent)(40)       | 26   | 1040                               |
| DC Motor(Shunt)(2200)            | 15   | 33000                              |
| 1 Phase IM(370)                  | 3    | 1110                               |
| DC Motor(Series)(2200)           | 2    | 4400                               |
| Socket(80)                       | 67   | 5360                               |
| Computer-CPU(Lenovo)(360)        | 33   | 11880                              |
| Resistive Load Bank(2200)        | 5    | 11000                              |
| Slipring IM(3700)                | 1    | 3700                               |
| 3ph IM(2200)                     | 5    | 11000                              |
| Synchronous Motor(3720)          | 1    | 3720                               |
| DC Rectifier(11500)              | 1    | 11500                              |
| DC Generator(2500)               | 2    | 5000                               |
| DC Generator(1600)               | 4    | 6400                               |
| Alternator(1491)                 | 3    | 4473                               |
| Alternator(2237)                 | 2    | 4474                               |
| <b>Total Connected Load</b>      |      | <b>120849W</b><br><b>120.849kW</b> |




*ii. Mechanical Department-*

| Equipment Name (Rating in Watts) | Qty. | Total Consumption                  |
|----------------------------------|------|------------------------------------|
| Fan(40)                          | 88   | 3500                               |
| Tubelight(LED)(18)               | 12   | 216                                |
| Tubelight(Fluorescent)(40)       | 133  | 5320                               |
| Exhaust Fan(40)                  | 2    | 140                                |
| Table Fan(40)                    | 9    | 360                                |
| Computer(100)                    | 213  | 21300                              |
| Socket(80)                       | 150  | 12160                              |
| Printer(Canon)(50)               | 5    | 250                                |
| Projector(Dell)(300)             | 10   | 3000                               |
| Water Purifier(180)              | 1    | 180                                |
| Air Conditioner(1440)            | 4    | 5760                               |
| Exhaust Fan(70)                  | 2    | 140                                |
| Scanner(10)                      | 2    | 20                                 |
| Wifi Router(80)                  | 3    | 240                                |
| <b>Total Connected Load</b>      |      | <b>150251W</b><br><b>150.251kW</b> |



iii. Computer Department-


| Equipment Name (Rating in Watts) | Qty. | Total Consumption                |
|----------------------------------|------|----------------------------------|
| Fan(40)                          | 57   | 2280                             |
| Tubelight(LED)(18)               | 12   | 216                              |
| Tubelight(Fluorescent)(40)       | 83   | 3320                             |
| Computer(100)                    | 125  | 12500                            |
| Printer(50)                      | 9    | 450                              |
| Projector(300)                   | 4    | 1200                             |
| Water Purifier(180)              | 1    | 180                              |
| Sockets(80)                      | 86   | 6880                             |
| Wifi Router(80)                  | 2    | 160                              |
| UPS(300)                         | 2    | 600                              |
| Server(2000)                     | 4    | 8000                             |
| AC(1440)                         | 4    | 5760                             |
| <b>Total Connected Load</b>      |      | <b>41546W</b><br><b>41.546kW</b> |



iv. IT Department-

| Equipment Name (Rating in Watts) | Qty. | Total Consumption |
|----------------------------------|------|-------------------|
| Fan(40)                          | 63   | 2520              |


|                             |     |                                 |
|-----------------------------|-----|---------------------------------|
| Tubelight(LED)(18)          | 9   | 162                             |
| Tubelight(Fluorescent)(40)  | 87  | 3440                            |
| Computer(100)               | 137 | 13700                           |
| Printer(50)                 | 12  | 600                             |
| Projector(300)              | 4   | 1200                            |
| Water Purifier(180)         | 1   | 180                             |
| Sockets(80)                 | 93  | 7440                            |
| Wifi Router(80)             | 3   | 240                             |
| UPS(300)                    | 2   | 600                             |
| Server(2000)                | 4   | 8000                            |
| AC(1440)                    | 3   | 4320                            |
| <b>Total Connected Load</b> |     | <b>42402W</b><br><b>42.402W</b> |



v. Civil Department-


| Equipment Name (Rating in Watts) | Qty. | Total Consumption |
|----------------------------------|------|-------------------|
| Fan(40)                          | 65   | 2600              |
| Computer(100)                    | 55   | 5500              |
| Tubelight(Fluorescent)(40)       | 81   | 3240              |
| Printer(50)                      | 6    | 300               |
| Projector(300)                   | 12   | 3600              |
| Inductive Load Bank(2300)        | 2    | 4600              |
| Socket(80)                       | 102  | 8160              |
| Capacitive Load Bank(3680)       | 2    | 7360              |
| Resistive Load Bank(2200)        | 2    | 4400              |

|                             |   |                                  |
|-----------------------------|---|----------------------------------|
| 1ph IM(872)                 | 1 | 872                              |
| 3ph IM(2200)                | 5 | 11000                            |
| Water Purifier(180)         | 2 | 360                              |
| Wifi Router(80)             | 7 | 560                              |
| Exhaust Fan(70)             | 3 | 210                              |
| Bell(16)                    | 2 | 32                               |
| <b>Total Connected Load</b> |   | <b>45988W</b><br><b>45.988kW</b> |




*D. Final Analysis-*

After the final calculations, we have found that the total energy consumption of the Institution is 445.883kW and the total energy consumption in the electricity bill is 430.231kW.



*vi. E&TC Department-*

| Equipment Name (Rating in Watts) | Qty. | Total Consumption                |
|----------------------------------|------|----------------------------------|
| Fan(40)                          | 82   | 3280                             |
| Halogen(45)                      | 12   | 540                              |
| Tubelight(Fluorescent)(40)       | 130  | 3280                             |
| Printer(35)                      | 11   | 385                              |
| Projector(300)                   | 11   | 3300                             |
| Scanner(11)                      | 2    | 22                               |
| Sockets(80)                      | 184  | 14720                            |
| Computer(100)                    | 133  | 13300                            |
| Water Purifier(180)              | 2    | 360                              |
| Xerox Machine(1500)              | 1    | 1500                             |
| Wifi Router(80)                  | 3    | 240                              |
| <b>Total Connected Load</b>      |      | <b>44847W</b><br><b>44.847kW</b> |



**IV CONCLUSION-**

Energy audits provide a unique pathway for customers to save money. Energy conservation and cutting utility costs are extremely important as energy prices rise. Energy auditing is not an exact science, but a number of opportunities are available for improving the accuracy of the recommendations. Techniques which may be appropriate for small-scale energy audits can introduce significant errors into the analyses for large complex facilities. We found the difference between our calculated total energy consumption and the total energy consumption in the campus electricity bill. We also addressed several problem areas which can result in over-optimistic savings projections, and suggested ways to prevent mistakes. Finally, several areas where additional research, analysis, and data collection are needed were identified. Once this additional information is obtained, we can all produce better and more accurate energy audit results.

**ACKNOWLEDGMENT –**

I would like to express our gratitude towards my guide and mentor Prof. A. S. PANDEY for his valuable advice, positive criticism, and consistent encouragement. I would also like to thank all department faculty and HoD(EE) for their valuable feedback, without which this work would not have been completed.

**REFERENCES –**

- [1] Vivek Jadhav, Rushikesh Jadhav, Pramod Magar, Sandip Kharat, Mr. S. U. Bagwan, "Energy Conservation through Energy Audit," in International Conference on Trends in Electronics and Informatics 978-1-5090-4257-9/17/2017 IEEE
- [2] Xin. Wang, and Chen. Huang, Wuwei. Cao, "Energy Audit of Building: A Case Study of A Commercial Building in Shanghai," Leading Academic Discipline Project of Shanghai Municipal Education Commission (J50502) and "Special Research Fund in Shanghai Colleges and "the National Natural Science Foundation of China (No.50478113)" universities to Select and Train Outstanding Young Teachers (slg09011)
- [3] R. Saravanakumar, Naga Chetan, Pranav chakaravarthy, Karthickkeyan, Sava rakesh, Ramkiran, "M Energy Audit Report," 3rd International Conference on Advances in Electrical, Electronics, Information, Communication and Bio-Informatics (AEEICB17) 978-1-5090-5434-3©2017 IEEE
- [4] Ramya.L.N, "A Case Study on Effective Consumption of Energy using Sensor Based Switching System," IEEE Sponsored 2nd International Conference on Innovations in Information Embedded and Communication Systems ICIECS'15
- [5] Mr.Mandar S. Isasare, Prof.Swapnil a. zadey, "A Case Study: Energy Audit at AVBRB, Sawangi (M), Wardha," International Conference on Electrical, Electronics, and Optimization Techniques (ICEEOT) 978-1-4673-9939-5/16 ©2016 IEEE
- [6] Harapajan Singh, Manjeevan Seera, Mohamad Adha Mohamad Idin "Electrical Energy Audit in a Malaysian University - A Case Study," IEEE International conference on power and energy(PECon),2-5 december 2012, kota Kinabalu sabah Malaysia 978-1-4673-5019-8/2012 IEEE
- [7] Jian Zhang, Yuchen Zhang, Song Chen, Sizhuo Gong, "How to Reduce Energy Consumption by Energy Audits and Energy Management," 978-1-890843-23-6/11/ 2011 IEEE
- [8] Nitin Kumar & Jitender Singh (2017). "ENERGY AUDIT OF A COLLEGE"